



Chhattisgarh State Electricity Regulatory Commission

Civil Lines, G.E. Road, Raipur – 492001

Tel: 0771-5073555, Fax-5073553

Petition No. 42/2005(M)

M/s Slasar Sponge & Power Ltd. — Petitioner
V/s
Chhattisgarh State Electricity Board, Raipur - Respondent

Copy of Order sheet dated 20.12.2005

It is informed by the CSEB that for correct metering of power the ideal ratio for import/export or export/import of power should be 1:20. This is acceptable to the Commission. In the instant case, the export of power is to the tune of 13500 KW and import is 1500 KW which is well within this limit.

In view of the above, the Commission permits reduction in contract demand from 4000 KVA to 1500 KVA at 132 KV to M/s Salasar Sponge and Power Ltd. for startup power provided suitable metering arrangement is made.

Sd/-
Member

Sd/-
Chairman

True Copy

(N.K.Rupwani)
Secretary